



PLANNING, ZONING AND BUILDING DEPARTMENT
Town of Palm Beach
360 S County Rd
Palm Beach, FL 33480

DEVELOPMENT REVIEW COMMITTEE REPORT

DRC MEETING: 4/6/21

APPLICATION NO.: Z-21-00353 **APPLICATION TYPE:** SITE PLAN REVIEW

ADDRESS: 1080 S OCEAN BLVD

DESCRIPTION: Section 134-843(b): Request for Site Plan Review to allow the construction of a 9,485 square foot two-story, single family residence on a non-conforming platted lot that is 17,567 square feet in area in lieu of the 20,000 square foot minimum required in the R-A Zoning District.

<u>DEPARTMENT</u>	<u>NAME/TITLE</u>	<u>DATE</u>	<u>COMMENT</u>
BUILDING OFFICIAL	Wayne Bergman, Director, Planning, Zoning & Building	4/22/2021	No Comment
PUBLIC WORKS DEPARTMENT	Craig Hauschild, Civil Engineer	6/1/2021	- Stormwater Management calculation have not been provided. - Safe Sight Triangle needs to be dimensioned for the intersection of Kings Road and S. Ocean Blvd, to confirm compliance with Section 134-1637. - Keeping the driveway onto South Ocean Blvd does not meet Public Works requirements. - Sight triangles for the driveways onto Kings Road do not appear consistent with Public Works requirements. Dimensions required for review.
FIRE RESCUE DEPARTMENT	Martin DeLoach, Fire Marshal	4/22/2021	There are no fire code concerns with this proposed project.
PZB - PLANNING AND ARCHITECTURAL REVIEW	Laura Groves Van Onna, Historic Preservation Planner	4/29/2021	This proposed project is on the tentative agenda for the regularly scheduled Architectural Commission (ARCOM) meeting on 05/26/2021 as Application B-042-2021.
PZB DIRECTOR	Wayne Bergman, Director, Planning, Zoning & Building	4/22/2021	No Comment
PZB - ZONING	Paul Castro, Zoning Administrator	4/26/2021	I have no zoning comments on this project.